DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: **Beach Grove Elementary** Date: **September 7, 2005**

Surveyor: **Barry O'Regan (ACM Environmental Corporation)**

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
13						X											12" Grey/Green Vinyl Floor Tile with dark and white streeks (hub room)
41						X											12" Beige Vinyl Floor Tile with large red-brown streaks (<1%) (storage)
42						X											12" Beige Vinyl Floor Tile with large red-brown streaks (<1%) (storage)
43						X											12" Beige Vinyl Floor Tile with large red-brown streaks (<1%) (storage)
45						X											12" Beige Vinyl Floor Tile with brown and white streaks (<1%) (girls changeroom)
49						X											12" Beige Vinyl Floor Tile with brown and white streaks (<1%) (boys changeroom)
49A						X											12" Beige Vinyl Floor Tile with brown and white streaks (<1%) (paper storage)
50						X											12" Grey/Green Vinyl Floor Tile with dark and white streeks (gym entrance area)
51						X											12" Beige Vinyl Floor Tile with brown and white streaks (<1%) (gym storage)
60						X											12" Beige Vinyl Floor Tile with small brown streaks (<1%) (east corridor)
60						X											12" Grey/Green Vinyl Floor Tile with dark & white streaks (N, S & W corridors)

Legend

1	ASBESTOS IN ABOVE-CEILING SPACES	5	ASBESTOS ON VISIBLE PIPING AND/OR DUCTING
2	ASBESTOS ON CEILING SURFACES	6	ASBESTOS IN FLOORING MATERIAL
3	ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD)	7	ASBESTOS IN FIRE DOORS
4	ASBESTOS IN BELOW-FLOOR AREAS	8	ASBESTOS IN WINDOW PUTTY