

DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: Chalmers Elementary

Date: June 13, 2012

Surveyor: Barry O'Regan (ACM Environmental Corporation)

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
All	X				X												Mechanical Pipe Insulation
100						X											Olive Vinyl Floor Tile with White Streaks (<1%) (centre block corridor)
101			X														Drywall Joint compound (<1%) (staff room)
101C						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (staff room storage)
102						X											Beige Vinyl Floor Tile with Orange and White Streaks (<1%) (hub room)
107					X												Mechanical Pipe Insulation (boys changeroom)
108					X												Mechanical Pipe Insulation (girls changeroom)
109						X											Olive Vinyl Floor Tile with White Streaks (<1%) (gym storage)
116						X											Olive Vinyl Floor Tile with White Streaks (<1%) (pod A north corridor)
121						X											Olive Vinyl Floor Tile with White Streaks (<1%) (pod A south corridor)
130						X											Beige Vinyl Floor Tile with Orange and White Streaks (<1%) (counselling office)
131						X											Beige Vinyl Floor Tile with Orange and White Streaks (<1%) (a/v storage)
134C						X											Beige Vinyl Floor Tile with Orange and White Streaks (<1%) (custodial)
138						X											Olive Vinyl Floor Tile with White Streaks (<1%) (pod E corridor)
139						X											Olive Vinyl Floor Tile with White Streaks (<1%) (pod E cloakroom)
140						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod E classroom)
141						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod E classroom)
142						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod E classroom)
143						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod E classroom)
144						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod E MP room)
145						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod E classroom)
149						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod D LA room)
150						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod D kindergarten)
151						X											Light Brown Vinyl Floor Tile with large Red Streaks (<1%) (pod D kindergarten)

Legend

- 1 ASBESTOS IN ABOVE-CEILING SPACES
- 2 ASBESTOS ON CEILING SURFACES
- 3 ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD)
- 4 ASBESTOS IN BELOW-FLOOR AREAS

- 5 ASBESTOS ON VISIBLE PIPING AND/OR DUCTING
- 6 ASBESTOS IN FLOORING MATERIAL
- 7 ASBESTOS IN FIRE DOORS
- 8 ASBESTOS IN WINDOW PUTTY

