

DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: Devon Gardens Elementary

Date: November 27, 2009

Surveyor: Barry O'Regan (ACM Environmental Corporation)

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
110						X											9" Grey Vinyl Floor Tile with Dark & White Streaks (storage under south stair)
124						X											12" Light Brown with Orange and White Streaks (<1%) (storage west of kindergarten)
128						X											12" Olive Green Vinyl Floor Tile (<1%) (kiln room)
129A						X											12" Olive Green Vinyl Floor Tile (<1%) (girls changeroom storage)
132B						X											12" Olive Green Vinyl Floor Tile (<1%) (storage east of boys changeroom)

Legend

- | | | | |
|---|---|---|---|
| 1 | ASBESTOS IN ABOVE-CEILING SPACES | 5 | ASBESTOS ON VISIBLE PIPING AND/OR DUCTING |
| 2 | ASBESTOS ON CEILING SURFACES | 6 | ASBESTOS IN FLOORING MATERIAL |
| 3 | ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD) | 7 | ASBESTOS IN FIRE DOORS |
| 4 | ASBESTOS IN BELOW-FLOOR AREAS | 8 | ASBESTOS IN WINDOW PUTTY |