

# DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: Heath Elementary

Date: September 28, 2005

Surveyor: James McArthur

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
All	X																Original Duct Mastic
109A						X											Vinyl Floor Tile (under Carpet) (<1%) (workroom)
114						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (LA room)
117					X												Original Duct Mastic (gym storage)
118					X												Original Duct Mastic (boys changeroom)
119					X	X											Original Duct Mastic, 12" Beige Vinyl Floor Tile with White and Orange Streaks (<1%) (girls changeroom)
119A						X											12" Beige Vinyl Floor Tile with White and Orange Streaks (<1%) (storage)
119B						X											12" Beige Vinyl Floor Tile with White and Orange Streaks (<1%) (toilet)
121					X												Original Duct Mastic (kitchen)
122					X												Original Duct Mastic (stage)
123					X												Original Duct Mastic (electrical)
124						X											12" Beige Vinyl Floor Tile with White and Orange Streaks (<1%) (storage)
126						X											12" Beige Vinyl Floor Tile with Dark Streaks (<1%) (copy room)

**Legend**

- |   |   |   |   |
|---|---|---|---|
| 1 | ASBESTOS IN ABOVE-CEILING SPACES            | 5 | ASBESTOS ON VISIBLE PIPING AND/OR DUCTING |
| 2 | ASBESTOS ON CEILING SURFACES                | 6 | ASBESTOS IN FLOORING MATERIAL             |
| 3 | ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD) | 7 | ASBESTOS IN FIRE DOORS                    |
| 4 | ASBESTOS IN BELOW-FLOOR AREAS               | 8 | ASBESTOS IN WINDOW PUTTY                  |