

# DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: Holly Elementary

Date: November 7, 2005

Surveyor: James McArthur

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
ALL	X																Original Duct Mastic (above ceiling) (except classrooms 113-117, 120-125)
104						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (classroom)
105						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (classroom)
106						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (classroom)
107						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (classroom)
133						X											12" Beige Vinyl Floor Tile with White and Orange Streaks (<1%) (cloakroom)
134						X											12" Beige Vinyl Floor Tile with White and Orange Streaks (<1%) (cloakroom)
135						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (custodial room)
137					X	X											12" Beige Vinyl Floor Tile with Red Streaks (<1%), Exposed Original Duct Mastic (girls changeroom)
137A						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (storage)
137B						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (storage)
138					X	X											12" Beige Vinyl Floor Tile with Red Streaks (<1%), Exposed Original Duct Mastic (boys changeroom)
138A						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (storage)
138B						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (storage)
139					X	X											12" Beige Vinyl Floor Tile with Red Streaks (<1%), Exposed Original Duct Mastic (gym storage)
143						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (custodial room)
145A						X											12" Beige Vinyl Floor Tile with White and Orange Streaks (<1%) (medical room)
152						X											12" Beige Vinyl Floor Tile with Red Streaks (<1%) (corridors)

**Legend**

- 1 ASBESTOS IN ABOVE-CEILING SPACES
- 2 ASBESTOS ON CEILING SURFACES
- 3 ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD)
- 4 ASBESTOS IN BELOW-FLOOR AREAS

- 5 ASBESTOS ON VISIBLE PIPING AND/OR DUCTING
- 6 ASBESTOS IN FLOORING MATERIAL
- 7 ASBESTOS IN FIRE DOORS
- 8 ASBESTOS IN WINDOW PUTTY