

DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: Ladner Elementary

Date: October 25, 2005

Surveyor: Barry O'Regan (ACM Environmental Corporation)

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
Court/Kiln						X											12" Beige Vinyl Floor Tile with Orange Streaks (<1%) (adjacent to 123)
118						X											12" Beige Vinyl Floor Tile with Orange Streaks (<1%) (MP room)
120						X											12" Beige Vinyl Floor Tile with Orange Streaks (<1%) (under carpet) (music room)
128						X											9" Olive Vinyl Floor Tile with Cream Streaks (paper storage)
129						X											9" Olive Vinyl Floor Tile with Cream Streaks (book storage)
149						X											12" Beige Vinyl Floor Tile with Orange Streaks (<1%) (girls changeroom)
153						X											12" Beige Vinyl Floor Tile with Orange Streaks (<1%) (boys changeroom)
154						X											12" Beige Vinyl Floor Tile with Orange Streaks (<1%) (boys changeroom toilet)

- Legend**
- | | | | |
|---|---|---|---|
| 1 | ASBESTOS IN ABOVE-CEILING SPACES | 5 | ASBESTOS ON VISIBLE PIPING AND/OR DUCTING |
| 2 | ASBESTOS ON CEILING SURFACES | 6 | ASBESTOS IN FLOORING MATERIAL |
| 3 | ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD) | 7 | ASBESTOS IN FIRE DOORS |
| 4 | ASBESTOS IN BELOW-FLOOR AREAS | 8 | ASBESTOS IN WINDOW PUTTY |