

DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: McCloskey Elementary

Date: December 7, 2005

Surveyor: James McArthur (ACM Environmental Corporation)

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
All					X												Grey Duct Mastic
All			X														Drywall Taping Compound (<1%) (excl. Rooms 109, 124)
Crawlspace				X													Original Cement Piping Materials
101						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (gym storage)
104						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (science storage)
106						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (boys changeroom)
107						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (kitchen)
111						X											12" Beige Vinyl Floor Tile with Orange and White Streaks (<1%) (general storage)
117						X											12" Beige Vinyl Floor Tile with Orange and White Streaks (<1%) (medical)
124						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (hub room)
125						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (custodial)
129						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (SW corridor)
130						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (NW corridor)
201						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod A kindergarten)
202						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod A kindergarten)
203						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod A classroom)
204						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod A classroom)
208						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod A cloakroom)
301						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod C classroom)
302						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod C classroom)
303						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod C classroom)
304						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod C classroom)
308						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod C cloakroom)
400						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod E corridor)

Legend

- 1 ASBESTOS IN ABOVE-CEILING SPACES
- 2 ASBESTOS ON CEILING SURFACES
- 3 ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD)
- 4 ASBESTOS IN BELOW-FLOOR AREAS

- 5 ASBESTOS ON VISIBLE PIPING AND/OR DUCTING
- 6 ASBESTOS IN FLOORING MATERIAL
- 7 ASBESTOS IN FIRE DOORS
- 8 ASBESTOS IN WINDOW PUTTY

DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: McCloskey Elementary

Date: December 7, 2005

Surveyor: James McArthur (ACM Environmental Corporation)

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
401						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod E classroom)
402						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod E classroom)
406						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod E storage)
407						X											12" Beige Vinyl Floor Tile with Large Orange Streaks (<1%) (pod E boys washroom)
501						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod D classroom)
502						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod D classroom)
503						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod D classroom)
504						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod D classroom)
508						X											12" Beige Vinyl Floor Tile with White and Dark Streaks (<1%) (pod D cloakroom)
608						X											12" Beige Vinyl Floor Tile with Orange and White Streaks (<1%) (pod B cloakroom)

Legend

- 1 ASBESTOS IN ABOVE-CEILING SPACES
- 2 ASBESTOS ON CEILING SURFACES
- 3 ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD)
- 4 ASBESTOS IN BELOW-FLOOR AREAS

- 5 ASBESTOS ON VISIBLE PIPING AND/OR DUCTING
- 6 ASBESTOS IN FLOORING MATERIAL
- 7 ASBESTOS IN FIRE DOORS
- 8 ASBESTOS IN WINDOW PUTTY