

DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: Seaquam Secondary

Date: December 5, 2005

Surveyor: James McArthur

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
All		X	X														Original Drywall, maybe be hidden by wall coverings (except 152A and 158A) Red duct mastic, concealed
Under Roof	X																Fireproofing, fibrous cement under the roof along metal beams
1F2			X														Cement Board Materials, in Fume Hoods (media arts)
1M1						X											12" Beige Vinyl Floor Tile (<1%) (NW classroom)
1M3						X											12" Beige Vinyl Floor Tile (<1%) (NW classroom)
103						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (north vestibule to large gym)
107						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair NW of large gym)
108						X											12" Beige Vinyl Floor Tile (<1%) (canteen)
109						X											12" Orange Vinyl Floor Tile (<1%) (corridor north of large gym)
110						X											12" Orange Vinyl Floor Tile (<1%) (north vestibule/stair between gyms)
111						X											12" Orange Vinyl Floor Tile (<1%) (corridor north of small gym)
113A						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (girls change vestibule)
114A						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (boys change vestibule)
117					X												Red Duct Mastic, Exposed (small gym storage)
119						X											12" Orange Vinyl Floor Tile (<1%) (south vestibule/stair between gyms)
121						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (south vestibule to large gym)
130						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (corridor south of cafeteria)
131						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair SW of cafeteria)
136						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (corridor west of stage)
137					X												Red Ducting Mastic (Exposed) (stage)
138					X												Red Ducting Mastic (Exposed) (auditorium)
141					X												Red Ducting Mastic (Exposed) (custodial lunch room, under aud. seating)
141A					X												Red Ducting Mastic (Exposed) (custodial storage, under aud. seating)

Legend

- 1 ASBESTOS IN ABOVE-CEILING SPACES
- 2 ASBESTOS ON CEILING SURFACES
- 3 ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD)
- 4 ASBESTOS IN BELOW-FLOOR AREAS

- 5 ASBESTOS ON VISIBLE PIPING AND/OR DUCTING
- 6 ASBESTOS IN FLOORING MATERIAL
- 7 ASBESTOS IN FIRE DOORS
- 8 ASBESTOS IN WINDOW PUTTY

DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: Seaquam Secondary

Date: December 5, 2005

Surveyor: James McArthur

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
141B					X												Red Ducting Mastic (Exposed) (custodial storage, under aud. seating)
141C					X												Red Ducting Mastic (Exposed) (custodial storage, under aud. seating)
142					X												Red Ducting Mastic (Exposed) (custodial, under aud. seating)
142A					X												Red Ducting Mastic (Exposed) (hub room, under aud. seating)
143					X												Red Ducting Mastic (Exposed) (boys washroom, east of auditorium)
144					X												Red Ducting Mastic (Exposed) (electrical room, east of auditorium)
145					X												Red Ducting Mastic (Exposed) (girls washroom, east of auditorium)
146						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair NW of cafeteria)
146A						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (storage under stair)
148						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (corridor north of cafeteria)
149						X											12" Orange Vinyl Floor Tile (<1%) (vestibule north of cafeteria)
150						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair NE of cafeteria)
152						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (staff room vestibule)
153						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (corridor north of kitchen)
159			X														Cement Board Materials, in Fume Hoods (kitchen)
162						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (main N-S corridor)
207						X											12" Beige Vinyl Floor Tile with White Streaks (<1%) (office) (custodial)
217						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair NE of cafeteria)
221						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair NW of cafeteria)
223						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair SW of cafeteria)
240						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair NE of library)
242					X												Red Ducting Mastic (Exposed) (north fan room)
245					X												Red Ducting Mastic (Exposed) (south fan room)
246						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair SE of library)

Legend

- 1 ASBESTOS IN ABOVE-CEILING SPACES
- 2 ASBESTOS ON CEILING SURFACES
- 3 ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD)
- 4 ASBESTOS IN BELOW-FLOOR AREAS

- 5 ASBESTOS ON VISIBLE PIPING AND/OR DUCTING
- 6 ASBESTOS IN FLOORING MATERIAL
- 7 ASBESTOS IN FIRE DOORS
- 8 ASBESTOS IN WINDOW PUTTY

DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: Seaquam Secondary

Date: December 5, 2005

Surveyor: James McArthur

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
261B						X											12" Beige Vinyl Floor Tile with White Streaks (<1%) (office)
262						X											12" Olive Vinyl Floor Tile with Dark and White Streaks (stair north of textiles)

Legend

- | | | | |
|---|---|---|---|
| 1 | ASBESTOS IN ABOVE-CEILING SPACES | 5 | ASBESTOS ON VISIBLE PIPING AND/OR DUCTING |
| 2 | ASBESTOS ON CEILING SURFACES | 6 | ASBESTOS IN FLOORING MATERIAL |
| 3 | ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD) | 7 | ASBESTOS IN FIRE DOORS |
| 4 | ASBESTOS IN BELOW-FLOOR AREAS | 8 | ASBESTOS IN WINDOW PUTTY |