

# DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: South Delta Secondary

Date: September 7, 2005

Surveyor: James McArthur (ACM Environmental Corporation)

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
All	X	X	X														Duct Mastics - All original ducting in unexposed areas (ie. Above Ceilings) Drywall Joint Compound (excluding exposed roof fan room, rooms 137, 148A, 151C, 198C, & Library Area and excluding non-exposed 176-181, 189, 195, 195A-E)
001						X											12" Beige Vinyl Floor Tile (<1%) (drama workshop under aud. seating)
118						X											12" Green Vinyl Floor Tile with White and Dark Streaks (<1%) (ESL classroom)
119						X											12" Green Vinyl Floor Tile with White and Dark Streaks (<1%) (computer lab)
121						X											12" Green Vinyl Floor Tile with White and Dark Streaks (<1%) (computer lab)
125A						X											12" Beige Vinyl Floor Tile (<1%) (tech ed seminar room)
125B						X											12" Beige Vinyl Floor Tile (<1%) (auto shop office)
130						X											12" Beige Vinyl Floor Tile (<1%) (resource room)
130B						X											12" Beige Vinyl Floor Tile (<1%) (resource room storage)
130C						X											12" Beige Vinyl Floor Tile (<1%) (resource room office)
133						X											12" Green Vinyl Floor Tile with White and Dark Streaks (<1%) (corridor north of stage)
142						X											12" Beige Vinyl Floor Tile (<1%) (gym storage)
142A						X											12" Green Vinyl Floor Tile with White and Dark Streaks (<1%) (foods room)
150						X											12" Beige Vinyl Floor Tile (<1%) (cafeteria)
150B						X											12" Beige Vinyl Floor Tile (<1%) (cafeteria storage)
150D						X											12" Beige Vinyl Floor Tile (<1%) (staff dining room)
151					X												Duct Mastic, Exposed Ducting (stage)
151C						X											12" Beige Vinyl Floor Tile (<1%) (stage storage)
152					X												Duct Mastic, Exposed Ducting (auditorium)
152B		X															Ceiling Texture (SW auditorium stair)
152C		X															Ceiling Texture (auditorium projection room)
152D		X															Ceiling Texture (NW auditorium stair)

**Legend**

- 1 ASBESTOS IN ABOVE-CEILING SPACES
- 2 ASBESTOS ON CEILING SURFACES
- 3 ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD)
- 4 ASBESTOS IN BELOW-FLOOR AREAS

- 5 ASBESTOS ON VISIBLE PIPING AND/OR DUCTING
- 6 ASBESTOS IN FLOORING MATERIAL
- 7 ASBESTOS IN FIRE DOORS
- 8 ASBESTOS IN WINDOW PUTTY

# DELTA SCHOOL DISTRICT ASBESTOS MANAGEMENT PROGRAM

Building: South Delta Secondary

Date: September 7, 2005

Surveyor: James McArthur (ACM Environmental Corporation)

Room No.	AREA CONTAINS WRAPPED OR NON-FRIABLE ASBESTOS, DO NOT DISTURB								AREA CONTAMINATED WITH ASBESTOS, SPECIAL ENTRY PROCEDURES REQUIRED								Comments
	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	
159						X											12" Green Vinyl Floor Tile with White and Dark Streaks (<1%) (copy room)
160A						X											12" Beige Vinyl Floor Tile (<1%) (workroom south of staff room)
163C						X											12" Beige Vinyl Floor Tile (<1%) (library cloakroom)
164						X											12" Beige Vinyl Floor Tile (<1%) (corridor east of library, under staircase)
165						X											12" Beige Vinyl Floor Tile (<1%) (custodial east of library)
203					X												Duct Mastics - Fume Hood (chemistry room)

**Legend**

- |   |   |   |   |
|---|---|---|---|
| 1 | ASBESTOS IN ABOVE-CEILING SPACES            | 5 | ASBESTOS ON VISIBLE PIPING AND/OR DUCTING |
| 2 | ASBESTOS ON CEILING SURFACES                | 6 | ASBESTOS IN FLOORING MATERIAL             |
| 3 | ASBESTOS ON WALLS (DRYWALL OR CEMENT BOARD) | 7 | ASBESTOS IN FIRE DOORS                    |
| 4 | ASBESTOS IN BELOW-FLOOR AREAS               | 8 | ASBESTOS IN WINDOW PUTTY                  |